बिहार सरकार

Office of Sub Divisional Officer
Public Health Sub Division, Ara

Letter No:...578...

Date:-28/10/2026

Certificate regarding safe drinking water condition

It is certified that an inspection team headed by Sri. Arun Kumar, Assistant Engineer, from Public Health Engineering Department, Ara inspected the **Mount Litera Zee School, Arrah** on 24-10-2026 and founded that **Mount Litera Zee School, Arrah** has safe drinking water facilities for students and members of staff of institution and is maintaining the hygienic condition in school building & the Campus.

28/10/26

Signature with Seal:-.....अवर प्रमण्डल पदाधिकारी
लोक स्वास्थ्य अवर प्रमण्डल

Name:-ARUN KUMAR अरुण

Designation:-Assistant Engineer

Government of Bihar
Public Health Engineering Department
Monthly Water Quality Monitoring Report

District Name :Bhojpur Division Name: P.H. Division, Ara

Sample Collected By : Lab Staff

Date of Sampling :- 24/10/2026
Date of Testing :- 28/10/2026

S	Block	Panchayat	Village	Location of Source	Ward No.	Parameters															Remarks
						pH	Turb	EC	TDS	TH	Ca	Mg	Cl	Alka	Fe	NO_3	SO_4	F	As	Total Coli	
1	Ara	Nagar Nigam		Water Sample of Mount Litera Zee School, Arrah	-	7.14	0.2	508	330	285.12	64.76	31.39	30.19	383.8	0.07	NT	NT	NT	<0.001	-ve	Safe
						6.5-8.5	1	-	500	200	75	30	250	200	1	45	200	1	0.01	-	
Permissible Limit in absence of alternative source						NR	5	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	-	

*NT = Not Tested, BDL=Below Detection Limit

28/10/2026

Research Assistant
(Chemist)
P.H. Division, Ara

Research Assistant
DLWQTL,
P.H. Div, Ara