

PRFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.

NO. 191

DATE: 18/03/2025

It is certified that an inspection team headed by (SUB DIVISIONAL ENGINEER) from WATER SUPPLY AND SANITATION, SUB DIVISION, TARN TARAN inspected the MOUNT LITERA ZEE SCHOOL, TARN TARAN (PB) on 12.03.2025 and found that the MOUNT LITERA ZEE SCHOOL, TARN TARAN has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/ State/ U.T Govt.

The above valid for a period of 11.03.2026



Sub-Divisional Engineer
Water Supply & Sanitation
Sub Division, Tarn Taran

Signature with Seal :
Designation : SUB DIVISIONAL ENGINEER

MOUNT LITERA ZEE SCHOOL,
TARN TARAN

DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.
dwtl1@gmail.com



TC-14758

TEST REPORT

Name & Address of Customer : Mount Itera Zee School Khadoor Sahib Road , Tarn Taran	Customer Reference No.	No : 705 Dated : 07/03/2025
	Sample Submitted by	Mr. Hardeep Singh
	Date of Sample Receipt	07/03/2025
	Analysis Starting Date	07/03/2025
	Analysis completion Date	08/03/2025
Discipline : Chemical Testing		Group: Water
ULR No.:	TC14756250000042F	Sample Type : Water
Test Report No.:	DWTLTT/2425/00386	Date of Issue : 08/03/2025
Registration no.:	DWTLTT/REG2425/00850	Condition of Sample : Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle: 1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth : NA / NA
Village :	Not Mentioned	Habitation : Not Mentioned
Block:	Not Mentioned	District : Tarn Taran
Latitude :	Not Mentioned	Longitude: Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.55@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	338	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.11@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	292	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	224	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	51.30	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	23.33	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	19.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduced wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr. Mohammad Naushad Alam
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Tarn Taran

End of the Test Report