




Jangipur WTP Sub District Water Testing Laboratory
(Under Murshidabad Division P.H.E. Dte.)


Public Health Engineering Department, Govt. of West Bengal


Jangipur, Murshidabad, West Bengal, PIN -742213

Sample Code:-	JSDL-01/25/003	Type of Source:-	SUBMERSIBLE WATER				
Sample Package Condition:-		Sample Receive Date:-	07-04-2025				
a. Quantity of Sample Received- 500ml b. Type of Container-PP(Poly Propylene)		Type of Sample :-	Drinking Water				
		Sampling Protocol:-	Sample is collected by Laboratory person				
Customer Address:-	MOUNT LITERA ZEE SCHOOL JANGIPUR, VILL+HABI-TALAI, P.O-JARUR, BLOCK-RAGHUNATHGANJ-I, DIST-MURSHIDABAD, PIN-742235						
Sample Location:-	NEAR CANTEEN (TAP WATER)						
Sample Collected By:-	MD KASEM ALI (BACTERIOLOGIST)	GRN No - 192025260019376665					
TEST REPORT							
Test Started On-	07-04-2025				Test Completed On-	09-04-2025	
Sl.	Test Parameters	Method	Parameters tested is either NABL/Non-NABL scope	Units	Requirements IS 10500-2012		Results
					Acceptable Limit	Permissible Limit	
1	Colour	APHA 24 th Edition – 2120- Colour Method B (Platinum Cobalt Visual Comparison)	NABL	HU	5	15	<5
2	Odour	IS 3025(Part 5):2018	NABL	-	Agreeable	Agreeable	Agreeable
3	Taste	IS 3025(Part 8):2023	NABL	-	Agreeable	Agreeable	Agreeable
4	pH	IS 3025(Part 11):2017	NABL	-	6.5-8.5	No Relaxation	7.33
5	Turbidity	IS 3025(Part 10):2023	NABL	NTU	1	5	0.98
6	Total Hardness (as CaCO ₃)	IS 3025(Part 21):2009	NABL	mg/l	200	600	240
7	** Iron (Fe)	Complexometry followed by Photometry	Non-NABL	mg/l	0.3	1	0.11
8	** Arsenic (As)	IS 3025(Part 37):1988 ; SDDC Method	Non-NABL	mg/l	0.01	No Relaxation	0.001
9	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Total Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0
10	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Faecal Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0

Note : (**) marked parameters are not under NABL scope


16/04/25
Chemist
Jangipur WTP Water Testing Laboratory, P.H.E. Dte.
P.H. Engg. Dte.


16/04/25
Bacteriologist
Jangipur WTP SD Laboratory
P.H. Engg. Dte.


17/04/25
Assistant Engineer (H.Q.)
Murshidabad Division
P.H.E. Dte.

*Drinking Water- Bureau of Indian Standards (BIS) IS:10500:2012, Drinking Water Specification 2012 and Amendment No. 01-06-2015

* Remarks - Water Test report shows all the parameters tested are with permissible limit, Hence the water is safe.



Jangipur WTP Sub District Water Testing Laboratory
(Under Murshidabad Division P.H.E. Dte.)

Public Health Engineering Department, Govt. of West Bengal
Jangipur, Murshidabad, West Bengal, PIN -742213

Sample Code:-	JSDL-01/25/002	Type of Source:-	SUBMERSIBLE WATER
Sample Package Condition:-		Sample Receive Date:-	07-04-2025
a. Quantity of Sample Received- 500ml b. Type of Container-PP(Poly Propylene)		Type of Sample :-	Drinking Water
		Sampling Protocol:-	Sample is collected by Laboratory person
Customer Address:-	MOUNT LITERA ZEE SCHOOL JANGIPUR ,VILL+HABI -TALAI, P.O-JARUR, BLOCK-RAGHUNATHGANJ-I, DIST-MURSHIDABAD, PIN-742235		
Sample Location:-	SCHOOL BUILDING (TREATED WATER)		
Sample Collected By:-	MD KASEM ALI (BACTERIOLOGIST)	GRN No-	192025260019376665

TEST REPORT

Sl.	Test Parameters	Method	Parametes tested is either NABL/Non-NABL scope	Units	Test Completed On-		Results
					Requirements IS 10500-2012		
					Acceptable Limit	Permissible Limit	
1	Colour	APHA 24 th Edition – 2120- Colour Method B (Platinum Cobalt Visual Comparison)	NABL	HU	5	15	<5
2	Odour	IS 3025(Part 5):2018	NABL	-	Agreeable	Agreeable	Agreeable
3	Taste	IS 3025(Part 8):2023	NABL	-	Agreeable	Agreeable	Agreeable
4	pH	IS 3025(Part 11):2017	NABL	-	6.5-8.5	No Relaxation	7.36
5	Turbidity	IS 3025(Part 10):2023	NABL	NTU	1	5	1.02
6	Total Hardness (as CaCO ₃)	IS 3025(Part 21):2009	NABL	mg/l	200	600	244
7	** Iron (Fe)	Complexometry followed by Photometry	Non-NABL	mg/l	0.3	1	0.1
8	** Arsenic (As)	IS 3025(Part 37):1988 ; SDDC Method	Non-NABL	mg/l	0.01	No Relaxation	0.001
9	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Total Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0
10	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Faecal Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0

Note : (**) marked parameters are not under NABL scope

Spal
16/04/25
Chemist
Jangipur WTP Water Testing Laboratory, P.H.E.Dte.

MAL
16/04/25
Bacteriologist
Jangipur WTP SD Laboratory, P.H.E.DTE

AD
17/04/25
Assistant Engineer
Murshidabad Division P.H.E. Dte.

*Drinking Water- Bureau of Indian Standards (BIS) IS:10500:2012, Drinking Water Specification 2012 and Amendment No. 01-06-2015

* Remarks - Water Test report shows all the parameters tested are with permissible limit, Hence the water is safe.



**Jangipur WTP Sub District Water Testing Laboratory
(Under Murshidabad Division P.H.E. Dte.)**

Public Health Engineering Department, Govt. of West Bengal


Jangipur, Murshidabad, West Bengal, PIN -742213

Sample Code:-	JSDL-01/25/001	Type of Source:-	SUBMERSIBLE WATER
Sample Package Condition:-		Sample Receive Date:-	07-04-2025
a. Quantity of Sample Received- 500ml b. Type of Container-PP(Poly Propylene)		Type of Sample :-	Drinking Water
		Sampling Protocol:-	Sample is collected by Laboratory person
Customer Address:-	MOUNT LITERA ZEE SCHOOL JANGIPUR, VILL+HABI-TALAI, P.O-JARUR, BLOCK-RAGHUNATHGANJ-I, DIST-MURSHIDABAD, PIN-742235		
Sample Location:-	NEAR OFFICE (RAW WATER)		
Sample Collected By:-	MD KASEM ALI (BACTERIOLOGIST)	GRN No -	192025260019376665

TEST REPORT


Test Started On-		07-04-2025			Test Completed On-		09-04-2025
Sl.	Test Parameters	Method	Parametes tested is either NABL/Non-NABL scope	Units	Requirements IS 10500-2012		Results
					Acceptable Limit	Permissible Limit	
1	Colour	APHA 24 th Edition – 2120- Colour Method B (Platinum Cobalt Visual Comparison)	NABL	HU	5	15	<5
2	Odour	IS 3025(Part 5):2018	NABL	-	Agreeable	Agreeable	Agreeable
3	Taste	IS 3025(Part 8):2023	NABL	-	Agreeable	Agreeable	Agreeable
4	pH	IS 3025(Part 11):2017	NABL	-	6.5-8.5	No Relaxation	7.4
5	Turbidity	IS 3025(Part 10):2023	NABL	NTU	1	5	18.6
6	Total Hardness (as CaCO ₃)	IS 3025(Part 21):2009	NABL	mg/l	200	600	248
7	** Iron (Fe)	Complexometry followed by Photometry	Non-NABL	mg/l	0.3	1	0.11
8	** Arsenic (As)	IS 3025(Part 37):1988 ; SDDC Method	Non-NABL	mg/l	0.01	No Relaxation	0.002
9	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Total Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0
10	** Bacteriological Analysis	15185 ;Membrane Filtration Technique (Faecal Coliform)	Non-NABL	CFU/100ml	0	No Relaxation	0

Note : (**) marked parameters are not under NABL scope


16/04/25

Chemist

Chemist
Jangipur WTP Water Testing
Laboratory, P.H.E.Dte.
P.H. Engg. Dte.


16/04/25

Bacteriologist

Bacteriologist
Jangipur WTP Water Testing
Laboratory, P.H.E.Dte.
P.H. Engg. Dte.


17/04/25

Assistant Engineer (H.O)

AE/HQ
Murshidabad Division
P.H.E.Dte.

*Drinking Water- Bureau of Indian Standards (BIS) IS:10500:2012, Drinking Water Specification 2012 and Amendment No. 01-06-2015

* Remarks - Water Test report shows all the parameters tested are with permissible limit except Turbidity , Hence the water is safe .

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHE/MURD/LAB/TR/APRIL/25-26/25

Dated: 23/04/2025

It is certified that an inspection team headed by Lanka Dae

(Name of Officers with designation) from Assistant Engineer, Jangipur Sub-Division PHED

inspected the P.H.U. No. 1

(Name & Address of the school) on 27-04-2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. JCM-01/025/003 dated 07-04-2025

of (PHED Lab) certified that

the MOUNT LIBERA ZEE SCHOOL, JANGIPUR (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till

Signature with Seal: Lanka Dae
Name: Lanka Dae
Designation: A.E. (C.M.D.)
Name & Address of the Office / Department:

To Principal (R. Mohan)
Mount Libera Zee School,
(Name & Address of the Institution)

7 ch Dae Road Bahampore,
PAN - 742101,

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Govt. of West Bengal Public Health Engineering GRIPS eChallan



192025260019376665

GRN Details

GRN: 192025260019376665 **Payment Mode:** Debit Card Payment
GRN Date: 16/04/2025 07:24:22 **Bank/Gateway:** State Bank of India
BRN : IK0DEXGRB7 **BRN Date:** 16/04/2025 07:33:43
GRIPS Payment ID: 160420252001937665 **Payment Init. Date:** 16/04/2025 07:24:22
Payment Status: Successful **Payment Ref. No:** 07-04-2025
[REF No]

Depositor Details

Depositor's Name: Md. Imtazul Hussain
Address: Mount Litera Zee School Jangipur, Talai, Jarur, Raghunathgan Murshidabad , West Bengal, 742235
Mobile: 9851859365
Depositor Status: Depositor
R.E.F. No: 07-04-2025
Name: Md. Imtazul Hussain
Address: Mount Litera Zee School Jangipur, Talai, Jarur, Ra
Period From (dd/mm/yyyy): 07/04/2025
Period To (dd/mm/yyyy): 14/04/2025
Remarks: M.L.Zee School

Payment Details

Sl. No.	Payment Ref No	Head of A/C Description	Head of A/C	Amount (₹)
1	07-04-2025	Collection of fees earned through testing of Private Water Samples in PHE Department Laboratories	0215-01-104-002-27	4200
			Total	4200

IN WORDS: FOUR THOUSAND TWO HUNDRED ONLY.