


Annexure-C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE



No.: AN-20 / 2026-2027

Date: 20/05/26

It is certified that an inspection team headed by DR. BABU CHAVAN
(Name of Officer with Designation) from UPHC Ashok Nagar PHED
Inspected the MOUNT LITERA ZEE SCHOOL, KALABURAGI
(Name & Address of the school) on 20/05/26 (Date of Inspection) and on the basis of Water
Test Report (Attached) bearing no PDACEK/CED/TEST/2026/894 dated 18/05/26
of PDACEK (PHED Lab) certified that the
MOUNT LITERA ZEE SCHOOL, KALABURAGI (Name of the School) has safe
drinking water facilities for the students and members of staff of the institution. School also
maintains the hygienic sanitary condition in the school building & the campus as per norms
prescribed by the Central / State / U.T. Govt.
This certificate is valid till 19/05/27

Signature with seal: DR. BABU CHAVAN

Name: DR. BABU CHAVAN

Designation: AMO

Name & Address


of the Office / Department: ಶಿವಮೊಗ್ಗ ನಗರ ಕಲಬುರಗಿ

To MOUNT LITERA ZEE SCHOOL

BEHIND HIGH COURT, AFZALPUR ROAD, KALABURAGI.

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer /PHED Lab / local bodies



AFFILIATED TO VTU BELAGAVI &
APPROVED BY AICTE
ACCREDITED BY NBA NEW DELHI

Hyderabad Karnataka Education Society's

Poojya Doddappa Appa College of Engineering

KALBURGI - 585 102 - KARNATAKA - INDIA

ಹೈದರಾಬಾದ ಕರ್ನಾಟಕ ಶಿಕ್ಷಣ ಸಂಸ್ಥೆಯ

ಪೂಜ್ಯ ದೊಡ್ಡಪ್ಪ ಅಪ್ಪ ಕಾಂತ್ರಿಕ ಮಹಾವಿದ್ಯಾಲಯ

ಕಲಬುರ್ಗಿ - ೫೮೫ ೧೦೨ - ಕರ್ನಾಟಕ

Phone : 08472-2224360-220019-220349 - Offi.: 220172 - Resi.: 228479 - Fax : 255685
Email : principal@pdaengg.com - principalpda@yahoo.com - Website : www.pdaengg.com

PDACEK/CED/TEST/2026/ 894

To,
Administrator
Mount Litera Zee School
Kalaburagi

Date: 18.05.2026


Sir,
Sub: Test results of R.O Water sample Supplied by you reg.
Ref. No.: Your Letter No: NIL/Dated: 13.05.2026
Rec. No: U89133/2025-26/Date: 04.05.2026/Rs. 1770/-

With reference to above-cited subject, the test results of R.O Water sample supplied by you are as follows

Sl. No.	Parameter	Results of R.O Water	As per IS 10500: 1991 Drinking water specification	
			Requirement (Desirable limits)	Permissible limits (if no alternative source)
1	Total Hardness as CaCO_3	120 mg/L	300 mg/L	600 mg/L
2	Chlorides	32 mg/L	250 mg/L	1000 mg/L
3	pH	7.5	6.5 to 8.5	No relaxation
4	Calcium Hardness as CaCO_3	72 mg/L	75 mg/L	200 mg/L
5	Magnesium Hardness	48 mg/L	30 mg/L	100 mg/L
6	Alkalinity as CaCO_3	80 mg/L	200 mg/L	600 mg/L
7	Total Solids	170 mg/L	---	---
8	Dissolved	170 mg/L	500 mg/L	2000 mg/L
9	Suspended Solids	0 mg/L	---	---
10	iron	0.25 mg/L	---	---
11	Fluoride	0.5 mg/L	0.5 mg/L	1.5 mg/L

This is for your kind information.
Thanking you.

Yours faithfully


Principal

PRINCIPAL
POOJYA DODDAPPA APPA
COLLEGE OF ENGINEERING
KALABURAGI-585102