

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 179

Dated: 25/09/2026

It is certified that an inspection team headed by Ravi Prakash, Executive Engineer

(Name of Officers with designation) from P.H. Division, Bhabua, PHED

inspected the Mount Litera Zee School, Darauli, Kaimur

(Name & Address of the school) on 25.09.2026 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 179/2026 dated 24.09.2026

of DLWT-Lab, Bhabua (PHED Lab) certified that

the Mount Litera Zee School (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till March-2027

Signature with Seal:

Name

Designation

Name & Address of the Office / Department: PHED

To Mount Litera Zee School

Vill + PO - Darauli, P.S. Bhabua, Kaimur - 821101

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Government of Bihar
Public Health Engineering Department
District Level Water Testing Laboratory - Public Health Division - Bhabua
Drinking Water Quality Test Monitoring Report



Report No. - 179/2026

Zone - Patna

District - Kaimur (Bhabua)

Issue Date - 24-09-2026

Sl. No.	Block	Panchayat / Town	Village / Locality	Habitation / Ward No.	Source of sample	Sample received date	Final Tested date	pH	Turb	EC	TDS	T. Hard	Ca	Mg	T. Alka	Cl	NO3	F	T. Coli	Remarks	
1	BHABUA	Mount Litera Zee School, Add- Vill + PO - Darauh, P.S. - Bhabhua, Dist. - Kaimur - 821101			Ground Water	18-09-26	24-09-26	7.49	0.05	237.23	154.20	42.00	8.40	5.10	52.00	11.00	BDL	0.06	A		
Desirable Limit								6.5-8.5	1.0	—	500	200	75	30	200	250	45	1	*A = Absent / *p = Present		
Permissible limit in absence of alternate source (IS 10500-2012) 2nd revision								NR	5.0	—	2000	600	200	100	600	1000	NR	1.5			

Note :- All the parameter tested in this laboratory are found within the maximum permissible limit.

* Above given details of Water Sample collected and submitted in laboratory for water quality test. Sample submitted by SCHOOL STAFF (Employee)

Ashok Kumar
24/09/2026
Chemist / Asst. Chemist
DLWT- Lab, P.H. Division,
Kaimur (Bhabua)

[Signature]
24/9/26
Executive Engineer
Public Health Division
Kaimur (Bhabua)

* BDL = Below Detection Limit

* NT = Not Test

* A = Absent

* P = Present

* This Test Report shall not reproduced without the permission of District Level Water Testing Laboratory, Bhabua.

* The reserved part of sample(s), except perishable sample(s), shall be returned for 15 day's from the date of issue of the Test report