सत्यमेव जयते

Goverment of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
English Bazar Fire Station, Ghorapir, Malda. Pin :- 732101

Memo No.:FSR/0125186230800170

Date : 29-11-2025

From :
Divisional Fire Officer
Malda Division,
West Bengal Fire & Emergency Services

To :
MOUNT LITERA ZEE SCHOOL
Chanchal, Mouza- Paharpur, JL no-149, Dag no-470, KH No-1383,3051, P.S- Chanchal, Pin - 732123, Dist- Malda

Sub : Issuance of Fire Safety Certificate of Existing construction of G+2 storied Educational Building under group of Educational in the name of MOUNT LITERA ZEE SCHOOL Owner of Mr Satyajit Saha at the Premises no:Chanchal,Mouza-Paharpur,J.L.No-149,Dag No-470,Khatian No-1383,3051,P.S-Chanchal,Dist-Malda,Under Chanchal Gram Panchyet.

This is in reference to your AIN 211892506300008446 dated 12-Oct-2025 regarding Issuance of Fire Safety Certificate of Existing construction of G+2 storied Educational Building under group of Educational in the name of MOUNT LITERA ZEE SCHOOL Owner of Mr Satyajit Saha at the Premises no:Chanchal,Mouza-Paharpur,J.L.No-149,Dag No-470,Khatian No-1383,3051,P.S-Chanchal,Dist-Malda,Under Chanchal Gram Panchyet..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Fire Safety Certificate** for occupancy of the aforesaid building.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
2. Periodical flashing of water in the Hydrant shall be made to maintain the efficiency of the above mentioned system.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008446

3. To eliminate risk of Fire Hazards, Good Housekeeping both for insides and outside of the building shall be strictly maintained.
4. Existing Electrical wiring of the whole building shall have to be carefully checked for any ware and tear in there, particularly lines above false ceiling & ducts.
5. The notice of Fire Fighting and evacuation from the building shall be prepared and displayed at all vulnerable of the building.
6. Regular Mock fire Practices and evacuation drill should be conducted periodically by participation of all the occupants of the building and for this purpose a special crew should be formed.
7. A Crew of trained fire man should be maintained round the clock for the safety of the building.
8. Adequate number of NO SMOKING boards should be displaying surrounding the premises.
9. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
10. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
11. If required the old line shall have to be replace with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
12. Transformer and Switch Gear room shall be protected with automatic Co2 or D.C.P. Fire extinction conforming I.S. Specification.
13. The Fire Safety Audit to be conducted at in a regular interval and to record in the Fire Prevention Maintenance register.
14.Fire license to be obtained from this end for the premises (if any) which attracts sec-12 of the fire Services Act.
15. The Fire Safety Certificate is valid for 3(Three) years and has to be renewed after three years from the date of issue of this letter As per Govt. of West Bengal Vide Notification No-629_L Dated-17/04/2018.
16. After three years a certificate is to be obtained from the West Bengal Fire & Emergency Services

Valid Upto : 27-Nov-2028

Memo No.:FSR/012518623080017[illegible]

Signature valid
Digitally Signed.
Name: SHIBA NANDA BARMAN
Date: 29-Nov-2025 13:30:33
Reason: D-Sig
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211892506300008446