

DISTRICT PUBLIC HEALTH LABORATORY BULDANA
REPORT ON BACTERIOLOGICAL EXAMINATION OF WATER

Email: mcbuldana@gmail.com

Phone : 7262242318

Name & Address of Sender		Mount Litera Zee School, Gut No. 65, 66, 67, Kolara, Tq.Chikhli, Dist. Buldana		
Sender's Letter No & Date		Date : 25/10/2025		
Laboratory Reference No.		4260		
Date of Collection		Date : 25/10/2025		
Date of Arrival at Laboratory		Date : 25/10/2025		
Date of Commencing Examination		Date : 25/10/2025		
Sr.No.	Particular of Water Samples	Result of Analysis – Most Probable Number per 100 Coli		
		Coli Forms	Thermo Tolerant Coli forms	E.Coli
1	Drinking Water sample before R.O. Filter	>16	03	---
2	Drinking Water sample after R.O. Filter	0	---	---

Remark: - Above water sample No 1 is unfit and Sample No.2 is fit for drinking purposes However it they can be used, only after proper treatment, chlorination and retesting bacteriological to ascertain its/their fitness for drinking purposes.

Note: - Above water sample were not collected by this laboratory.

R.No. 4260

Date : 25/10/2025

Rs. 700/-

Report Outward No.: 4260


Date:- 30/10/2025


PRINCIPAL

Mount Litera Zee School,
Chikhali, Dist. Buldhana Pin-443201


Manager

Mount Litera Zee School,
Chikhali, Dist. Buldhana Pin-443201


आरोग्य निरीक्षक
नगर परिषद, बुलढाणा