

# Annexure-C

Appendix-XIII

## PEROFORMA FOR SAFE DIRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.:- 1229

Date:- 13/08/2026

It is certified that an inspection team headed by **Vishwambhar Kumar Mandal**, Assistant Engineer From Public Health Sub-division, Samastipur inspected the **MOUNT LITERA ZEE SCHOOL, MOHIUDDINPUR CHOWK, SAMASTIPUR** on **12.08.2026** and found that the **MOUNT LITERA ZEE SCHOOL** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T Govt.

Signature with Seal.....

13/08/26

Name :- **Vishwambhar Kumar Mandal**

Designation :- **Sub Divisional Officer**  
P.H. Sub. Division, Samastipur

TO,

**PRINCIPAL,**

**MOUNT LITERA ZEE SCHOOL,  
MOHIUDDINPUR CHOWK, SAMASTIPUR**

*Amir Kumar*  
Manager  
Mount Litera Zee School



**Government of Bihar**  
**Public Health Engineering Department**

| DISTRICT :- SAMASTIPUR                                                  |             |              |      | DIVISION :- SAMASTIPUR                |            |       |     |           |          |          |           | MONTH:-AUGUST 2026 |          |         |        |   | REMARKS |
|-------------------------------------------------------------------------|-------------|--------------|------|---------------------------------------|------------|-------|-----|-----------|----------|----------|-----------|--------------------|----------|---------|--------|---|---------|
| S.N.                                                                    | BLOCK       | PANCHAYAT    | WARD | LOCATION OF SOURCE                    | PARAMETERS |       |     |           |          |          |           |                    |          |         |        |   |         |
|                                                                         |             |              |      |                                       | pH         | TURB  | EC  | TDS       | TH       | Ca       | Cl        | Mg                 | Alka.    | Fe      | T.COLI |   |         |
| 1                                                                       | WARIS NAGAR | MOHIUDDINPUR | 9    | MOUNT LITERA ZEE SCHOOL<br>SAMASTIPUR | 7.1        | 1     | 185 | 120       | 52       | 18       | 24        | 10                 | 58       | 0.1     | -Ve    |   |         |
| Acceptable Limit as per BIS 10500/2012                                  |             |              |      |                                       | 6.5-8.5    | 1 NTU | -   | 500 mg/l  | 200 mg/l | 75 mg/l  | 250mg g/l | 30 mg/l            | 200 mg/l | 1.0mg/l |        | - |         |
| Permissible Limit* in Absence of Alternate source as per BIS 10500/2012 |             |              |      |                                       | NR         | 5 NTU | -   | 2000 me/l | 600 me/l | 200 me/l | 1000 mg/l | 100 mg/l           | 600 mg/l | NR      |        | - |         |

Report  
13/08/26  
TE

13/08/26  
AE

Manager  
Mount Litera Zee School

Chemist/Lab Assistant  
P.H. Division Samastipur

